




ALGECO  
Mr. Jean GEMAYEL  
Roumieh LEBANON  
Tel : 01874 343

LEBANON AGENCY

Ref. MF/HO/13.0886

Beyrouth, 14 August, 2013

<b>TEST REPORT</b>			
<b>PROJECT:</b>	<b>LOADING TEST – GLAZED PARTITION</b>	<b>CODE :</b>	<b>DATE :</b>
		13.0886	14-08-2013
<b>File No. :</b>	<b>013.0179</b>	<b><u>COPIES</u></b>	
<b>CONTROL</b>	<b>CONTROL MADE FOLLOWING OUR PROPOSAL Ref : MF/HO/13.0859 du 01-08-2013</b>		
<b>STAGE :</b>	<b>Test</b>		
	<b>ASPECT OF CONTROL</b>	<b>AUTHOR OF THE REPORT</b>	
		<b>Haïssam Osman</b>	
		<b><u>Signature :</u></b>	
			
	<b>STRENGTH</b>	<b>PERSONAL SAFETY</b>	
	<b>Attachments :</b>	<b>No. of Pages : 4</b>	

Contact : Tel. 01 328 189 – Fax : 01 218 310 – email address: haïssam.osman@socotec-liban.com  
SOCOTEC Liban – S.A.R.L au capital de 200 000 000 LL – R.C. 65654 Beyrouth  
Siège Social : 51, rue Ferneini, Fum El Hayek – Achrafieh – Beyrouth – LIBAN

ASPECT OF CONTROL STRENGTH PERSONAL SAFETY	PROJECT LOADING TEST GLAZED PARTITION	CODE  13.0886	DATE  14-08-2013
--	---	---------------------	------------------------

TEST REPORT

As part of our mission (to) **of** technical verification on the above matter, we assisted on 7<sup>th</sup> August 2013 to **verify** load test **performed** on a prototype of a glass partition in the company ALGECO - Rouhmieh Metn in the presence of:

- Monsieur Haïssam (SOCOTEC LIBAN)
- Monsieur Jean GEMAYEL (ALGECO)

**Description of the prototype**

The glass has a rectangular shape: length = 2.80 m and width = 1.20 m. It concerns a glass that is supported on both sides in the metal frame (whichever is greater scope: L = 2.80m). The glass is tempered - type = 12mm thickness. The glazing is supported (taken in rebate) by fasteners type SELF-LOCK MINI PRO from CENTURY GLASS LLC

