

TEST
CERTIFICATE

This is to Certify that

Century Glass LLC – Dubai, U.A.E

Have submitted the

Century Self Lock Glazing System

Comprising of 10mm tempered glass
mounted on Frame size -1535^{mm} w x 3635^{mm} h

Which has successfully completed testing
to the requirements of the United Kingdom's:

Centre for Window & Cladding Technology
(CWCT) 2nd Edition – Section 10 – Ultimate Test

To a test pressure of 5310 Pa
without displacement or structural failure of the
system

All results of this test are fully documented in
Wintech report – no. IDH/R939/05/747

Dated 1st August 2005


.....
R W Withers

Technical/ Quality Manager, Wintech Engineering Ltd

24th July 2007
.....